
Scalable Microgrids for Enhancing Energy System Resiliency and Efficiency


Peng Zhang
University of Connecticut
April. 21, 2014



Storrs Campus Microgrid


- A Co-Generation Plant
 - 3 gas turbines of 7.2 MW each
 - 1 steam turbine 5 MW
 - 3 emergency diesels 4 MW
- Energy efficiency
 - The production of both electrical and steam allows over 80% of the fuel energy to be harnessed, versus 33% from a conventional power plant
 - Natural gas, a cleaner burning fuel, is used





http://energyservices.uconn.edu/SitePages/Home.aspx; User Name: FAS\PI, Password: Uconn2011

Enhanced electricity resiliency



Reduction of outage time by > 98%


Assuming UCONN CoGen availability: 98%

Utility grid availability: 99.5% (outage time 43.8 hrs)

⇒ UCONN power supply availability: 0.9999% (outage 0.88 hrs)

UCONN Depot Campus Microgrid


- UCONN received \$2.14M state funding to create a renewable microgrid in collaboration with Schneider Electric, ClearEdge Power, and A/Z Corporation
- Advancing Connecticut's Energy Resiliency First-in-the-Nation Statewide Microgrid Program



Energy Efficiency


- The fuel cell has generated 6215 MWh of electricity with a total efficiency of about 55%
- The PV panel has generated 11.8888 MWh of electricity with a total of 18168 lbs carbon offset

Microinverter PV




Centralized PV





Overview of Microgrid Benefits



Environmental and Social Benefits:

- Energy saving and carbon footprint reduction
- Job opportunities
- Electrification of remote area, transportation...


Technical Benefits:

- Infrastructure resilience
- Energy loss reduction
- Improved power quality
- Congestion relief
- Stabilization of distribution and transmission

Economic Benefits:


- Initiator of local retail and service markets
- Hedging against risks- price volatility, outage, load growth...
- Aggregator of supply- and demand side- players
- Interest arbitrator for different stakeholders

Reliability benefit of microgrid options for selective locations (i.e., town centers or clusters of critical facilities)




Expected annual outage time under CAT3 storm (hours/year)

Expected annual outage time under CAT2 storm (hours/year)



Expected annual outage time under CAT1 storm Expected annual outage time under Tropical storm




Expected annual outage time under major storm

Expected annual outage time under normal

41


Capabilities Covering Key Aspects of Microgrids



Sample research thrusts

- Ultra-fast Programmable Communication Networks
- Optimal Power Flow in Microgrid
- Robust Integration of Intermittent Renewables
- Distributed Optimization of Microgrids Considering Demand Response
- Load/Generation Shedding for Microgrid Resilience
- Reliability Characterization of Microgrids
- Resilient DC Cabling Network

Enabling highly resilient and efficient microgrids through ultra-fast programmable networks



Thank you!